

TEST CERTIFICATE

Number: 2138573.02

Issued to: A. van der Hof Kabelfabriek BV
Ziel 1
4704 RS Roosendaal
The Netherlands

For the product: Instrumentation and Signal Cable

Trade name: BERAN-FLAM

Type/Model: BERAN-FLAM J-H(St)-H

Ratings: 1x2x0,8 mm - 20x2x0,8 mm
1x2x0,9 mm - 20x2x0,9 mm
1x2x1,0 mm² - 20x2x1,0 mm²
1x2x1,5 mm² - 20x2x1,5 mm²
1x2x2,5 mm² - 20x2x2,5 mm²

Manufactured by: A. van der Hof Kabelfabriek BV
Ziel 1
4704 RS Roosendaal
The Netherlands

Requirements: EN 50200:2006

Remarks: This KEMA Quality Test Certificate is based on Test Reports nos. 266314-1 and 266314-2 of BRE, dated 16 November 2010.
The cables belongs to class PH 90.

This Test Certificate is granted on account of an examination by KEMA Quality, the results of which are laid down in a confidential file no 2138573.00.


The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA Quality is not the responsibility of KEMA Quality.

Arnhem, December 17, 2010

KEMA Quality B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed